



NOTES:

1. ALL WIRE TO BE #14 TYPE UNLESS SHOWN OTHERWISE.
2. TUBING WITH PRINTED WIRE NUMBERS, Omit THE LUG ON THE COMPRESSION OR SPOULGE TYPE TERMINAL.
3. DASHED LINES INDICATE FIELD WIRING.
4. GROUNDED 1/2 SIZE OF TRANSFORMER, 1 TO PAH.
5. GROUNDED 1/2 SIZE OF TRANSFORMER, 1 TO PAH.
6. CONNECTORS IN ADDITION BOX MUST BE WIPER-TIGHT. BRIDGES TERMINAL WILL REDUCE THE CAPACITY OF THE ADDITION BOX.
7. TO HELP PREVENT CONDENSATION ENTERING ENCLOSURE, INSTALL CONDUC TUBE WHICH SHALL BE 1/4" DIA. WITH VENT.

REFERENCE DRAWING

- GD-378 ASSEMBLY
- GB-482 FIELD WIRING (30)
- GA-2053 DOOR MACHINING
- GA-2054 DOOR MACHINING

DATE	BY	REVISION	DESCRIPTION	APP. NO.
12/12/80	WJH	1	ISSUE FOR PRODUCTION	1
<p>GENERAL NOTE: THE INFORMATION CONTAINED HEREIN IS CONFIDENTIAL AND IS THE PROPERTY OF NIELSON HEAT TRACING SYSTEMS. IT IS TO BE KEPT SECRET AND NOT TO BE DISCLOSED TO OTHERS WITHOUT WRITTEN PERMISSION.</p>				
<p>NIELSON HEAT TRACING SYSTEMS</p>			<p>REF: GD-378 ENVR</p>	
<p>1000 NORTH 12TH AVENUE, SUITE 200, DENVER, COLORADO 80202</p>			<p>ISSUE DATE 12/12/80</p>	
<p>PHONE: 438-8322, 800-541-5900 FAX: 438-8284-9488</p>			<p>DESIGNER WJH</p>	
			<p>CHECKED BY DMB</p>	
			<p>DATE OF ISSUE 12/12/80</p>	
			<p>SCALE NONE</p>	
			<p>PROJECT NO. 018</p>	
			<p>CD-379</p>	