

LEFT VIEW



FRONT VIEW

(NEMA 4 ENCLOSURE SHOWN)



COMPONENT VIEW



FORM P OPTION
TYPE Z PURGE SYSTEM
FRONT VIEW



FOUNDATION

NEMA 4 ENCLOSURE SHOWN



CAT. CM-2/GF-04



CAT. CM-2/GF-08



CAT. CM-2/GF-12



CAT. CM-2/GF-16



CAT. CM-2/GF-20



CAT. CM-2/GF-24



CAT. CM-2/GF-28



CAT. CM-2/GF-32



CAT. CM-2/GF-36

EQUIPMENT ARRANGEMENT FOR DOWNLOADED UNITS

SHOP NOTE: INSTALL SUFFICIENT MOUNTING RAIL FOR 40 CHS.

NOTES:

1. SECURE INSTRUCTION MANUAL, ITEM 39, INSIDE ENCLOSURE.
2. FINISH: NEMA 12 LT.GRAY EPOXY
   FINISH SPEC.: F800.091B
3. REFERENCE DRAWINGS:
   GD-0436 WIRING DIAGRAM
   GB-0511 FIELD WIRING
   GA-1934 DOOR MACHINING (NEMA 12, 4, 4X)

SHOP NOTES:

1. SHOP TO USE ITEMS 109 AND 110 TO MANUFACTURE AN ENCLOSURE DOOR GROUND STRAP.
2. ENCLOSURE HAS TWO GROUND BUSSES. MOUNT SECOND BUS IN SAME LOCATION ON OPPOSITE SIDE. SEE ENCLOSURE LEFT VIEW, THIS DRAWING.

THIS UNIT HAS RS484 COMMUNICATIONS CAPABILITY.

COMPANY CONFIDENTIAL - INFORMATION CONTAINED HEREIN IS CONFIDENTIAL, IT IS THE PROPERTY OF NELSON HEAT TRACED, IT IS TO BE USED SOLELY FOR THE PURPOSE PROVIDED, AND IT IS NOT TO BE DISCLOSED TO OTHERS WITHOUT PRIOR WRITTEN CONSENT OF NELSON HEAT TRACE.

REVISION	DATE	ASSEMBLY	REF: GD-0436	DATE
R.O. ISSUED FOR MANUFACTURE DMB	02/29/08	CIR. MANAGEMENT SYSTEM W/GND FAULT 40 CIRCUIT 277VAC MAX. NEMA 12,4,&4X	DSGN: DMB	02/29/08
			APPD: DMB	02/29/08
			DOC#: GD-0435	
		CAT. NO. CM2GF404R2 CLASS 319	SC: NONE	D/L
		CONFIDENTIAL PROPERTY OF NELSON HEAT TRACING SYSTEMS TULSA, OK, USA PHONE (918)627-5530 FAX (918)622-9308	GD-0435	R.O.